



**THE ESCAMBIA COUNTY SCHOOL DISTRICT
PURCHASING DEPARTMENT
75 NORTH PACE BLVD.
PENSACOLA, FL 32505**

AMENDMENT 1 REQUEST FOR PROPOSAL (RFP)

AMENDMENT POSTING DATE:

May 17, 2019

PURCHASING CONTACT & TELEPHONE:

**Travis Thrash; 850.469.6207
tthrash@escambia.k12.fl.us**

RFP TITLE:

Commercial Generator – Ransom Middle School

RFP NUMBER:

192703

RFP OPENING DATE & TIME:

NO CHANGE – Friday, May 31, 2019 2:00 PM, CENTRAL TIME

NOTE: PROPOSALS RECEIVED AFTER THE RFP OPENING DATE AND TIME WILL NOT BE ACCEPTED.

This Amendment shall serve to amend, replace, and append information provided to the potential Respondents in the original RFP package. To assist in the development of their responses, interested firms are encouraged to carefully review the information found in this Amendment.

The following information contained in the original RFP has been added, deleted, or replaced:

#1. Section IV.F. (page 10) is deleted in its entirety and replaced with the following Section IV.F.:

F. Installation and hookup services shall be “white glove,” as defined above, and shall include but not be limited to, connecting the generator to an existing natural gas line within close proximity of the generator’s location, installing one (1) natural gas cutoff valve on the generator apparatus, installing and connecting required electrical wiring, performing initial startup, and executing an eight (8) hour load bank test. This initial load bank test shall be performed immediately to ensure that the new generator is fully operational and working properly. A second, four (4) hour load bank test shall be performed within the final ninety (90) days of the third year of the warranty period.

#2. The following Section IV.Q. is added after Section IV.P. (page 12):

Q. The new generator shall be installed inside the mechanical room (Room 167) indicated in Attachment J. The exact location within the room shall be determined by the Maintenance Department and will be communicated after award. Responder must install an exhaust system through an appropriate point in the mechanical room’s walls. This exhaust system must meet or exceed requirements set forth by any and all federal, state, and local rules and regulations.

#3. The following Section IV.R. is added after Section IV.Q. (page 12):

R. The District shall provide a gas line, the size of which shall be appropriate relative to the generator model provided by the Responder, in close proximity to the location in which the new generator

is to be installed. Responder is responsible for the hookup of the generator to the existing natural gas line.

#4. Section V.A.6. (page 13) is deleted in its entirety and replaced with the following Section V.A.6.:

F. Provide copies of the licensure required to perform the work outlined in this RFP, including but not limited to, electrical licensure. If Responder is subcontracting any work related to this RFP, then the required licensure held by the subcontractor(s) must be provided. The licensure submitted shall be verified with the Florida Department of Business & Professional Regulation (DBPR). Pending licenses will not be accepted.

#5. Attachment I – Submission Checklist (Page 28) is amended as follows:

Attachment I is amended such that “6. Copies of Licensure Required for Performance of work (i.e. Electrical or Natural Gas Licensure)” is changed to “6. Copies of Licensure Required for Performance of work (i.e. Electrical Licensure)”.

#6. Attachment J:

The drawing attached to this Amendment is hereby added after Attachment I – Submission Checklist (page 28).

By signing below, the Responder acknowledges receipt of the Amendment for RFP #192703. Respondent must attach and return all pages of this Amendment with their Proposal.

RESPONDER (Firm Name): _____

PRINTED NAME OF AUTHORIZED REPRESENTATIVE: _____

SIGNATURE OF AUTHORIZED REPRESENTATIVE: _____

TITLE OF AUTHORIZED REPRESENTATIVE: _____

DATE: _____

Excerpt of FISH Drawings for Ransom Middle School

